



JOHN E. COREY JR., P.E.  
City Engineer

## City of Woburn Massachusetts

Engineering Department

Tel. (781) 897-5880  
Fax (781) 897-5889

**To:** Tina Cassidy, Planning Director  
**From:** Brett F. Gonsalves, Senior Engineer  
**Date:** February 28, 2017  
**Subject:** **Drew Place Status Update**  
**Previous Memo Dated May 23, 2016, December 1, 2015**

The applicant has requested final surety release for the above referenced subdivision. The submitted as-built plans and street acceptance plans have been reviewed and this office takes no exception the documents as submitted.

There is one stone bound in the sidewalk on the left side of the entrance that was low. The developer will install a square cast iron monument box over the stone bound. This will allow the surrounding surface to be brought to grade and eliminate the depression while maintaining access to the bound.

This is the only item that would prevent release of final surety.

I trust this information will suffice your needs and if you or the board have any questions concerning this information, do not hesitate to contact this office.